RABR-VAP Circular fire damper with constant pressure retention function



FIRE SAFETY



02/02/2022





E60/E120



Quick facts

- Fire resistance class E60S / E90S / E120S
- Sizes from 200 x 200 mm to 1500 x 1500 mm ٠
- Prefitted safety actuator 24V
- Slip joint connection, or Flange connection •
- Duct- or wall-mounted •
- Easy pressure retention
- Available in MagiCAD
- CE-marked building product in accordance ٠ with 15650:2010

Two dampers in one!

Bevent Rasch has developed a fire damper for fire resistance classes E60S / E90S / E120S which is also used for constant pressure retention in all types of ventilation plants whilst providing full protection against the spread of smoke.

Use

Damper in combination with walls or joists for fire-sectioning of heating, ventilation and air conditioning installations in buildings. accordance with the harmonised European Standard EN 15650:2010. Smoke spread is prevented when the damper system design in accordance with the associated documentation, assembly and fitting instructions is used in combination with smoke detectors and the MRB (or equivalent) monitoring system. No further measures against the spread of smoke are required. As the damper also functions as a constant pressure retention damper, both these functions are combined in the same damper. This saves both time, space and money for installations in, for example, hotels, office and shopping complexes, where both these functions need to be solved.

Performance

EEC certificate in accordance with 15650:2010 402-CPR-SC0899-13

Classification of fire resistance in accordance with EN 13501-3 E120 (ve ho i <-> o) S E90 (ve ho i <-> o) S E60 (ve ho i <-> o) S



For complete classification, see the Declaration of Performance.

Installation

RABR-VAP is mounted on horizontal or vertical ducts that run through fire compartment separated sections of the building, in accordance with the adjoining mounting instructions. Wall penetration RBVG is used for installation against building elements.

Design

RABR-VAP is supplied complete with a factory mounted, maintenance-free, 24 V electric safety actuator with thermal sensor featuring built-in signal contacts to indicate the damper position. The actuator is Belimo's specific VAV motor for stable and safe regulation. RABR-VAP is supplied prepared for possible overinsulation of 50 mm. RABR-VAP is supplied calibrated from the factory. Nominal pressure is 100 Pa or 300 Pa depending on the pressure sensor's range of measurement. Desired reference values are set using the regulator's potentiometer between 30-100% of nominal pressure. The reference value can be remotely set with a 2-10V signal from the DUC, for example. The device can be force-controlled to different operational requirements. In case of of a power failure, the damper closes with actuator spring return.



Activation

Smoke detectors must be verified in accordance with the Swedish standard SS-EN 54-7 for damper activation. The mandatory thermal sensor closes the damper at 72°C in accordance with ISO 10294-4.

Control and monitoring

When the damper is used as protection against fire and the spread of fire it shall close on activation of an impulse from smoke detector or thermal sensor. It shall be mounted in a ventilation duct close to the damper or another suitable location.

Smoke detectors are monitored with Bevent Rasch MRB or an equivalent system. The MRB monitoring system also carries out automatic function tests of dampers every 48 hours and is configured so that faults are immediately indicated and the damper is closed. For further information refer to the technical section on the website.

The following Bevent Rasch monitoring units can be used: • MRB3 with RCTC/RCTU

Size

Horizontal duct and joist-mounting*^{*} 200 x 200 mm to 800 x 900 mm.

Wall-mounting*) 200 x 200 mm to 1500 x 1500 mm.

*) For wall- or joist-mounting the RABR-VAP should be fitted in combination with the RBVG wall penetration.

Design

RABR-VAP is supplied calibrated from the factory. Nominal pressure is 100 Pa or 300 Pa depending on the pressure sensor's range of measurement. Desired reference values are set using the regulator's potentiometer between 30-100% of nominal pressure. The reference value can also be remotely set with a 2-10V signal from the DUC, for example. The device can be force-controlled to different operational requirements.

Material and surface finish

The casing and components are supplied as standard in hot-dip galvanized sheet steel in accordance with environmental class C3. For higher environmental classes the casing and components can be supplied in stainless steel.

Miscellaneous

All data presented are for dampers in standard versions. This type of damper shall not be confused with a Pressure Relief Damper which has the opposite function.

Specification

| Examples: Fire damper RABR-VAP - <u>600</u> - <u>400</u> - <u>1</u> - <u>1</u> - <u>0</u> - | 3 |
|---|---|
| Size Width x Height (W x H), mm | |
| Connection, see dimensional diagram Slip joint (max 800 x 900) = 1 Flange = 2 Slip joint/Flange = 3 | |
| Material Galvanized sheet steel = 1 Stainless AISI 316L - EN 1.4404 = 3 | |
| ActuatorWithout MRB unit= 0With MRB3 unit fitted (RCTU)= 5Note! Factory-fitted actuator is always included. | |
| Pressure sensor 30-100 Pa = 1 90-300 Pa = 3 | |

Note! Slip joint/Flange is adapted for fitting in combination with RBVG wall penetration. Shall be used in conjunction with wall- or joist-mounting.

Accessories

| RBVG | Wall penetration |
|-----------|-------------------------------------|
| BRAS | Circular sleeve connection for RABR |
| RCKB | Connection box |
| RCKD/-RD | Smoke detectors |
| RCTU/RCTC | MRB3 system, max 236 dampers |
| BRRM/BRMR | Measuring unit |



Dimensions and weight



RABR-VAP for mounting in combination with RBVG is supplied with Slip joint/Flange type 3 connector. RABR-VAP with height dimensions 250, 450, 650 and so on are supplied with raised slip joint or flange.

Number of damper blades

| Size W or H | Number of blades |
|----------------|---------------------|
| 200 | 1 |
| 300 | 2 |
| 400 | 2 |
| 500 | 3 |
| 600 | 3 |
| 700 | 4 |
| 800 | 4 |
| 900 | 5 |
| 1000 | 5 |
| 1100 | 6 |
| 1200 | 6 |
| 1300 | 7 |
| 1400 | 7 |
| 1500 | 8 |

Weight incl. actuator, kg

| | В | | | | | | | | | | | | | |
|------|-----|-----|-----|-----|-----|-----|-----|-----|------|------|------|------|------|------|
| w | 200 | 300 | 400 | 500 | 600 | 200 | 800 | 006 | 1000 | 1100 | 1200 | 1300 | 1400 | 1500 |
| 200 | 8 | 9 | 11 | 13 | 15 | 17 | 19 | 23 | 26 | 30 | 32 | 37 | 40 | 43 |
| 300 | 9 | 11 | 13 | 15 | 17 | 19 | 22 | 26 | 28 | 33 | 35 | 41 | 44 | 46 |
| 400 | 11 | 13 | 15 | 17 | 19 | 22 | 24 | 29 | 32 | 36 | 39 | 45 | 48 | 50 |
| 500 | 13 | 15 | 17 | 19 | 22 | 24 | 26 | 34 | 37 | 41 | 46 | 51 | 54 | 57 |
| 600 | 15 | 17 | 19 | 22 | 24 | 26 | 28 | 35 | 38 | 43 | 46 | 52 | 55 | 58 |
| 700 | 17 | 19 | 22 | 24 | 26 | 28 | 30 | 38 | 40 | 46 | 49 | 56 | 59 | 62 |
| 800 | 19 | 22 | 24 | 26 | 28 | 30 | 32 | 41 | 44 | 49 | 52 | 60 | 63 | 66 |
| 900 | 22 | 24 | 26 | 28 | 30 | 32 | 35 | 44 | 47 | 52 | 56 | 63 | 66 | 70 |
| 1000 | 24 | 26 | 28 | 30 | 32 | 34 | 36 | 47 | 50 | 56 | 59 | 67 | 70 | 74 |
| 1100 | 26 | 28 | 30 | 32 | 34 | 36 | 38 | 50 | 53 | 59 | 62 | 70 | 74 | 77 |
| 1200 | 28 | 30 | 32 | 34 | 36 | 38 | 40 | 53 | 56 | 63 | 66 | 74 | 78 | 82 |
| 1300 | 30 | 32 | 34 | 36 | 38 | 40 | 42 | 56 | 59 | 66 | 69 | 78 | 82 | 85 |
| 1400 | 32 | 34 | 36 | 38 | 40 | 42 | 44 | 59 | 62 | 69 | 73 | 82 | 86 | 89 |
| 1500 | 34 | 36 | 38 | 40 | 42 | 44 | 46 | 62 | 65 | 72 | 76 | 85 | 89 | 93 |

Mounting

The pressure sensor should be mounted in a representative position in the duct downstream of the damper with the arrow in the direction of the air flow. The measuring hose must be fixed in the duct and in the static pressure sensor on the damper. If the damper is placed in the supply air duct the measuring tube shall be moved to the minus spigot on the static pressure sensor. The pressure sensor is calibrated and mounted in a vertical position. When mounting in another position, post-adjustment on-site is possible.





Electrical data

| | RABR-VAP | VRP-STP |
|----------------------------|------------------------|--------------------|
| Sizing, max | 10 VA - BF24-V | 2,6 VA |
| Running time; | | |
| - motor opening | 120-300 s | |
| - spring return, max | approx. 20 s | |
| Protection class | IP 54 | |
| Power supply | 24V~ ±20%, 50/60 Hz | |
| - Control signal Y | | DC 2-10 V |
| | | DC 0-10 V (option) |
| - Measuring signal U | | DC 2-10 V |
| 0.1000/11 | | DC 0-10 V (option) |
| 0-100% U nom | | |
| Ambient temperature | | 0° to +50°C |
| End position contacts: | | |
| - load \leq 300 mW | min 1 mA/5V=, | |
| | max 100 mA/250V~ | |
| Applicable after exceeding | the above values: | |
| - load > 300 mW | min 100 mA, max 3 A/28 | 50~ |
| Sound level | | |
| - when opening | approx. 45 dB(A) | |
| - with spring return | approx. 62 dB(A) | |

Dimensioning diagram



Valid only for standard dimensions.

Sound data

Correction of sound power level, $\mathrm{L}_{\mathrm{w}}^{},$ for different sizes,

 $\mathbf{L}_{\mathrm{W}} = \mathbf{L}_{\mathrm{Wt}} + \mathbf{K}_{\mathrm{1}}$

| Damper | | | | | | | | |
|----------------------|------|------|------|-----|-----|------|----|------|
| area, m ² | 0,08 | 0,16 | 0,32 | 0,5 | 1 | 2 | 3 | 4 |
| K ₁ | -3 | 0 | 3 | 4,5 | 7,5 | 10,5 | 12 | 12,8 |

Correction of sound power level, $\mathrm{L}_{_{\mathrm{Wok}}}$, in octave band,

$$L_{Wok} = L_W + K_{ok}$$

Correction, K_{ok}

| Opening | Centre frequency Hz | | | | | | | | | |
|-----------|---------------------|------|------|-----|-----|-----|-----|--|--|--|
| angle | 125 | 4000 | 8000 | | | | | | | |
| 90° | -1 | -8 | -16 | -18 | -22 | -30 | -37 | | | |
| 45° | -10 | -3 | -6 | -8 | -12 | -21 | -31 | | | |
| 10° | -11 | -3 | -5 | -9 | -14 | -23 | -30 | | | |
| Tol. ± dB | 3 | 2 | 2 | 2 | 2 | 2 | 3 | | | |



Wiring diagram



E60/E120 Fire damper with constant pressure retention function RABR-VAP



Installation instructions for RABR-VAP together with wall penetration RBVG



Options 1 and 2

- 1. Install wall penetration RBVG in accordance with instructions (see separate installation instructions).
- 2. Apply fire stopping sealant around the edge of the wall penetration flange.
- 3. Affix the damper in wall penetration RBVG using M 8x12 screws.
- 4. Install the thermal sensor in the air stream without obstructing the movement of the damper blades.
- 5. If the fire damper is not connected to the duct system, fit non-combustible grilles designed for the damper on the unconnected sides.

- 6. Connect the actuator to the control unit and perform a function test.
- 7. Install the duct system in accordance with applicable requirements. Ensure that the connecting duct does not affect the damper when under a fire load.
- Minimum distance between dampers must be 200 mm.
- Minimum distance to joist structure/wall must be 75 mm.
- Install damper spindle horizontally
- Make sure the diagonal measurements of the duct are equal.



Installation instructions for RABR-VAP in insulated ducts



- 1. Install the damper in the duct with connection for slip joint or flange. Seal the connection with fire sealant, e.g. Intumex AN.
- 2. Mount the thermal sensor with the sensor body in the airflow without obstructing the movement of the damper blades.
- 3. The duct system is fitted in accordance with current requirements. Ensure that connecting ducts do not affect the damper at fire load.
- Duct going through building element, is sealed using an approved method, such as caulking with mineral wool, min 40kg/m³ and fire sealant.

- 5. Duct is fastened/supported according to applicable requirements.
- 6. Protect the duct according to applicable requirements using instructions from the fire rated duct supplier.

When installed inside a fire cell the duct is insulated in accordance with an approved method to prevent thermal damage to the structure (ducting system).

- Minimum distance between dampers must be 200 mm.
- Minimum distance to joist structure/wall must be 75 mm.
- Horizontal installation of the damper spindle.
- Make sure the diagonal measurements of the duct are identical.





Quick facts

• Sizes from 200 x 200 mm to 1500 x 1500 mm

Use

Penetration in combination with walls or joist structures to achieve an optimal damper or duct system connection. The penetration creates a tidy, sealed connection to the building element and requires neither refinishing nor painting. Also used in combination with smoke dampers for the fire separation of ventilation systems in buildings.

Design

The penetration is supplied complete with fixings for a flange connection and extenders for connection to a duct system.

Material and surface finish

As standard, casing and components of hot-dip galvanized steel sheet in accordance with environmental class C3. For a higher environmental class, stainless steel casing and components can be supplied.

Specification

| Example: Wall penetration RBVG - 500 - 300 - 300 - 0 - 1 |
|---|
| Size Width x Height (W x H), mm |
| Length, mm |
| Insulation, Without insulation = 0 |
| Connection, see dimensional drawing Flange, 30 mm = 1 |

Note. Lengths other than 300 mm shall be clearly specified.



Dimensions and weight



 $^{\ast)}$ Clearly specify lengths other than 300 mm when ordering.



Installation instructions for wall penetration RBVG



- Make a hole, corresponding to the duct's nominal dimensions + 10 mm, in the building element. If installing in plasterboard, a steel reinforcement frame must be used.
- 2. Apply fire rated sealant (such as Intumex AN) to the building element around the hole, approx. 10 mm from the edge.
- 3. Fit the cover plate over the wall penetration and affix the unit to the building element with the fire rated sealant.
- 4. Slide on the installation frame from the opposite side and affix with clamps or the like. Ensure that the cover plate and the fire rated sealant comprise a tight seal against the building element.
- 5. Lock the wall penetration in place in the installation frame with screws or blind rivets spaced 100-150 mm apart.
- 6. Attach the appropriate joint for the duct and connect.
- 7. If the duct system is not connected, for example, when installed as a termination device or transfer air device, fit non-combustible grilles designed for the damper on the unconnected sides. The minimum distance between the damper blade in the open position and the grille is 50 mm.