

## Declaration of Performance Rasch fire dampers

No: DoPX005100

**Product model:**

**BSKC9**

Type number and specification according to the product label.

**Intended use:**

To prevent fire and combustion gases in the ventilation system between compartments in buildings according to the harmonized European standard EN 15650:2010.

**Manufacturer**

Rasch AB  
Norrsten  
Motala  
[www.rasch.se](http://www.rasch.se)

**Assessment system and factory product control of the products performance:**

System 1

**Product certification:**

The notified body number 0402 SP, Technical Research of Sweden has performed control according to system 1.

- Initial type testing and initial inspection of the factory and the factory production control system
- Continuous surveillance, assessment and approval of factory production control and issued the certificate: no. 0402-CPR-SC0051-19

**Performance defined:**

Essential characteristics	Classification/Performance	Standard
Normal activation/sensitivity -Sensing element load bearing capacity -Sensing element response temperature	Pass	ISO 10294-4:2001
Response delay (response time) -Closure time	Pass	EN 1366-2:1999
Operational reliability -Cycling	50 cycles, Pass	EN 1366-2:1999
<b>Fire resistance:</b>		
-Integrity (E)	90 (ve ho i ↔ o)	EN 1366-2:1999 EN 13501-3:2005+A1:2009
-Insulation(EI)	90 (ve ho i ↔ o)	EN 1366-2:1999 EN 13501-3:2005+A1:2009
-Smoke leakage(-S)	S	EN 1366-2:1999 EN 13501-3:2005+A1:2009
Mechanical stability	Pass	EN 1366-2:1999
Maintenance of the cross section	Pass	EN 1366-2:1999
Durability of response delay: -sensing element response to temperature and load bearing capacity	Pass	ISO 10294-4:2001
Durability of operational reliability: -open and closing cycle tests	10 000 + 10 000 cycles Pass	EN 15650:2010

Performances of BSKC9 conform to performance by the above list.

The declaration of performance has established under Rasch AB own responsibility.

Signed for the manufacture



Anders Freyschuss CEO  
Motala 2021-02-17